

REGIONAL WATER TESTING LAB, HOSHIARPUR

Government ITI, Jalandhar Road, Hoshiarpur
rwtlhsp@gmail.com

To,

Bliss Public School
Manna, Phagwara Road, Hoshiarpur

No.: RWTLHSP/2324/00613 Dated : 02/09/2023

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. 1/25/23 Dated: 25/08/2023

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 26/08/2023. It is request to fill the attached feedback form and send it back to Regional Water Testing Lab, Hoshiarpur

D/A : 1 Test Report



Authorized Signatory
For, Regional Water Testing Lab
Hoshiarpur

REGIONAL WATER TESTING LAB, HOSHIARPUR

Government ITI, Jalandhar Road, Hoshiarpur
rwtlhsp@gmail.com

TEST REPORT

Name & Address of Customer : Bliss Public School Manna, Phagwara Road, Hoshiarpur	Customer Reference No.	No : 1/25/23 Dated : 25/08/2023
	Sample Submitted by	Pawan Kumar
	Date of Sample Receipt	26/08/2023
	Analysis Starting Date	31/08/2023
	Analysis completion Date	01/09/2023

Discipline : Chemical Testing, Bacteriological Testing		Group: Water	
ULR No.:		Sample Type :	Water
Test Report No.:	RWTLHSP/2324/00613	Date of Issue :	02/09/2023
Registration no.:	RWTLHSP/REG2324/00693	Condition of Sample :	Unsealed
Collection Point:	Treatment Plant (RO/CWPP/ARP/HH Purifier)	Quantity/Type of Bottle:	1000 ml / Amber Coloured Sample Bottle - 500 mL.
Scheme/Source:	Not Mentioned (Not Mentioned)	Location/Depth :	Manna, Phagwara Road, Hoshiarpur / NA
Village :	Not Mentioned	Habitation :	Not Mentioned
Block:	Not Mentioned	District :	Hoshiarpur
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	Colour	1	5	15	CU	IS 3025 (Part 4-2021) Visual Comparison Method
2	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
3	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
4	TDS	112.0	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
5	Turbidity	BDL	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
6	Alkalinity	81.9	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
7	Hardness	66.64	200	600	mg/l	IS 3025 (Part 21-2009)(RA 2019) EDTA Method
8	Calcium	17.28	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
9	Magnesium	5.71	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
10	Chloride	14.09	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

REGIONAL WATER TESTING LAB, HOSHIARPUR

Government ITI, Jalandhar Road, Hoshiarpur
rwtlhsp@gmail.com

11	Bacteriological Contamination	Absent	-	H2S Vial
----	-------------------------------	--------	---	----------

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed), ND=Not Detected
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: $25 \pm 5^{\circ}\text{C}$ and Humidity condition limit $50 \pm 20\%$



Mr. Jivesh Kumar
Quality Manager
Authorized Signatory
For, Regional Water Testing Lab
Hoshiarpur

----- End of the Test Report -----

REGIONAL WATER TESTING LAB, HOSHIARPUR

Government ITI, Jalandhar Road, Hoshiarpur
rwtlhsp@gmail.com

Payment Receipt

Receipt No. : 09917

Invoice No. : INV/2324/00693

Received From : Bliss Public School
Manna, Phagwara Road, Hoshiarpur

The Sum of Rupees : One Hundred Twenty Nine Only.
In Cash

Date : 26/08/2023

Invoice Date : 26/08/2023

Rs. : 129.00

Disclaimer: -Payment made by cheque/online mode are subject to clearance by bank.



ਖੇਤਰੀ ਪਾਣੀ ਪ੍ਰੀਖਣ ਪ੍ਰਯੋਗਸ਼ਾਲਾ,
ਜਲ ਸਪਲਾਈ ਅਤੇ ਸੈਨੀਟੇਸ਼ਨ ਵਿਭਾਗ,
ਹੁਸ਼ਿਆਰਪੁਰ।

For Regional Water Testing Lab, Hoshiarpur
Authorized Signatory